

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7271-1574:111 Page 1 of 1

CATEGORY: Ionization Smoke Detector

LISTEE: ADT Security Services, Inc., 695 Route 46 West, Fairfield, NJ 07004
Contact: *Ron Dalton (310) 725-2972 Fax (310) 725-2942

DESIGN: Model ADT-IS ionization smoke detector. Refer to listee's data sheet for detailed model descriptions and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as an ionization smoke detector for use with listee's separately listed compatible base (CSFM Listing No. 7300-1574:106) and fire alarm control units.

XLF: 7271-1591:124 Formerly 7271-1388:184

*Rev. 07-01-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JULY 1, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager